

Metasol Meta Solution EMPR Series Electronic Motor Protection Relays





EMPR replacing thermal overload relay is electronic motor protection relay which is used to protect the low voltage motor and also called as Electronic Overcurrent Relay or an Electronic Overload Relay.

As a digital motor protection relay with MCU, EMPR is highly reliable by implementation of realtime data processing and high precision and also can secure motor safely with various functions such as phase loss, phase reverse, unbalanced, stall, lock, ground fault, short circuit protection depending on the model.

EMPR has compact and simple appearance so it can be combined with the magnetic contactor. Various installation methods and separation of terminal block make easy design and manufacturing feature for MCC(Motor Control Center).

Especially, EMPR is EMC tested and approved to operate safely without any malfunction caused by electromagnetic wave and surge. Most of the models have received CE Mark and UL certification based on its product reliability.

Contents

Features	4
Ordering	7
Specification	8
Characteristics	12
Setting method	21
Dimensions	30
Wiring method	36
Accessories	39
EMPR Curves	41
Direct mounting EMPR new/old	42
comparative table	
Certificates	43







General Motor Protection Relay

GMP Series

- Various connection & mount
- Inverse or definite time protection mode
- Ground fault type
- Display the causes of the falut by LED



Digital Motor Protection Relay

- DMP Series
- Ampere meter, Load rate and the causes of fault Display
- Standard, Ground fault and short circuit protection type
- Select the Inverse or definite time protection mode
- Unit or Extension in one body by cable option
- Option function type (DMP-a)

Intelligent Motor Protection Relay

IMP Series

- Wide current setting range (0.125~100A)
- Communication support type (MODBUS. Analog)
- Zero current and residual current sensing
- Save the fault events and operating time setup
- Select the Inverse, thermal inverse or definite time modes

KOREAN STANDARDS ASSOCIATIC

Unit or Extension in one body by option cable



Electronic Motor Protection Relays

Features

GMP Series

Combination with Metasol contactors for compact motor starters

EMPR model	Contactor model
GMP22-2P/3P/3PR	MC-9b, MC-12b, MC-18b, MC-22b
GMP40-2P/3P/3PR	MC-32a, MC-40a

• Broad range of current setting

- Inverse time or definite time characteristics
- Simple operation and trip cause indication via LED
- Various Connection





Certification of CE, UL, CCC and S mark



• Various protection functions

Types (GMP-🗌)	2P, 2T, 2S	3P, 3T, 3S	3PR, 3TR, 3SR	3TN, 3TZ	3TNR, 3TZR
Number of sensors	2CT		3	СТ	
Overcurrent					
Phase failure					
Lock/Stall					
Phase unbalance					
Reverse phase					
Ground fault					

• Large current can be applied through additional current transformers

• MCU (Microprocessor Control Unit) built-in

- excellent reliability by achieving real-time data processing and high precision.
- Checking the last failure cause
 can be checked by pushing Test/Reset button twice in 0.5 seconds,
- Products for ground fault protection
- detecting of zero phase currents (ZCT used: GMP60-3TZ)
- detecting of residual currents (ZCT unused: GMP60-3TN)



Features DMP Series

Digital measuring and displaying

- Display digital ampere-meter
- Save the causes of the fault and the value
- Display motor load rate by graph



• Convenient structure

- Install the Unit / Extension type in one body The display part may be separated from the body You can check the values and the causes of the fault without opening the distribution panel door



- removable terminal block

• Various protection functions

Protection	DMP⊡-S/Sa	DMP -SZ/SZa	DMP□-SI	DMP⊡-T/Ta	DMP -TZ/TZa	DMP□-TI
Wiring		Screw type			Tunnel type	
Over current						
Under current						
Stall						
Lock						
Phase failure						
Reverse phase						
Phase unbalance						
Ground fault						
Short circuit						

• Trip curve selectable (Inverse/Definite)



Applicable to inverter control circuit

LS EMPR has high performance under the harmonic noise and can be used in the Inverter control circuit (20~200Hz), (except Ground fault model)

- Optional functions (DMP-a type)
- Storing up the last fault cause
- Storing up motor operation hours
- Checking replacement cycle of motor bearing by alarming

Features

IMP Series

The EMPR IMP series are optimal solutions for protecting and monitoring motors in complex industrial fields needed high safety and productivity.







~100A

Wide Current Setting Range: 0.125~100A for One Model

With the slide S/W, the current setting range can be decided 0.5~10A or 5~100A. Depending on the number of CT penetration, even 0.125A current can be protected. (Wire penetration hole is required).



Communication support type

RS-485 MODBUS communication with various systems. The model with analogue signals (4~20mA) is compatible with transducer systems.

Thermal Inverse Time,

Inverse Time and Definite Time Modes According to user's needs, the motor can be protected in the inverse time mode or definite time mode.



Wide Setting of Ground Fault Current Sensitivity 30mA~25A

zero current sensing by zero sequence CT. zero current sensing by Residual circuit.

Date and Total Operating Time Setup

When a fault occurs, its date and time are stored for easy checkup. When the total operation time is over, it is displayed for changing motor bearings or supplying oil.



Quick Setup

All settings can be decided quickly on the display.



Comprehensive Digital Motor Protection Relay with the MCU (Microprocessor Control Unit)

Real-time processing and high precision



One-Body Type and Separate Body Type

The display can be attached to the panel front so that current, operation time and settings can be checked without fetching the unit. With the display separated, the motor protection is available.



Applicable to Inverter Circuits

Thanks to its characteristics to harmonic noise, it can be applied to the inverter control circuits. The available frequency range is 20~200Hz. When the relative harmonic factor is over 30%, a harmonic filter should be installed (However, the ground fault function should be off).



Various Reset Functions

Manual, automatic and electric reset functions are provided for customer convenience.



Password

Settings are protected with a password.



Storage of Fault Events

Up to 5 fault events can be stored for easy fault history management.



3-Phase Digital Ampere-Meter

3-phase current is displayed every two seconds for motor monitoring.

Ordering

GMP Series



IDMP Series



Note) 1. Even the same model has different contact specifications. 2. When the power is applied, the system is in the contacting status.



Specification

GMP Series

Ratings								
Мо	odel	GMP22-2P/PD (1c)	GMP22- 2P(1a1b)	GMP22- 3P/3PR	GMP22-2S	GMP22- 3S/3SR	GMP22-2T	GMP22- 3T/3TR
Туре		Pir	n type		Scre	w type	Tunne	el type
No. of CT		2CT	2CT	3CT	2CT	3CT	2CT	3CT
Protection	Overcurrent	•	•	•	•	•	•	•
	Phase failure Note1)	•	•	•	•	•	•	•
	Lock/Stall	•	•	•	•	•	•	•
	Phase unbalance	—	-	•	—	•	_	•
	Reverse phase	_	-	●(3PR)	—	●(3SR)	—	●(3TR)
Current setting ran	ge (A)	0.3~1.5, 1~5, 4.4~22						
Operating time cha	racteristics	Inverse time (GMP22-2PD: D	Definite time)					
Time setting	Inverse time	0~30 sec						
(sec)	Definite D-time	0.2~60 sec for GMP22-2PD						
	O-time	5sec (Fixed) for GMP22-2PD)					
	Reset-time	Manual reset						
Tolerance	Current	±5%						
	Time	\pm 5%(or \pm 0.5sec)						
Control power	Voltage	AC 110V/220V(±10%)	AC 100~260	V				
	Frequency	50/60Hz						
Aux. contact	Contact	1SPDT: 1c (N) Note 3)		2SPST (1a1b	o)			
	Ratings	5A/250VAC Resistive load	3A/250VAC	Resistive load				
	Operate	(95 北 96 Close)	(95	ose) (s	97⊣⊦ 98 Open)			
Insulation resistant	ce	Min 100MΩ a	at 500Vdc					
Surge endurance (EC 61000-4-5)	5kV Apply the standard wave	е					
Fast transient burs	t (IEC 61000-4-4)	2kV						
Environment	Operation	-25~70 ℃						
Temperature	Storage	-30~80 °C						
	Relative humidity 30~90%RH(No freezing)							
Trip indicator		Red LED	Red/Green L	.ED	Red LED	Red/Green LED	Red LED	Red/Green LED
Dimension (mm)	$W \times H \times D$	44×71×78	53×78×87.	5	53×68×87	5	53×38×87.5	5
Mounting type		Direct mount onto a Metasol	MC (MC-9b-22b)	Separate mo	ount (Screw or Di	n-rail) Note2)	
Certification		UL, cUL, CE (Except GMP22-2PD type)						

 Note)
 1. When it is 2CT modle, only two-phase protection is available

 2. The bracket for Din-rail mount is optional
 3. 1c(N): No volt release contact type [1c(R), Non-fail-safe operation contact type is optinal]

Specification **GMP Series**

Rat	ings								
M	odel	GMP40- 2P/PD/PA	GMP40- 3P/3PR	GMP40-2S	GMP40- 3S/3SR	GMP40-2T	GMP40- 3T/3TR	GMP80- 2S/SA	GMP80- 3S/3SR
Туре		Pin	type *	Screv	v type	Tunne	el type	Screv	v type
No. of CT		2CT	3CT	2CT	3CT	2CT	3CT	2CT	3CT
Protection	Overcurrent	•	•	•	•	•	•	•	•
	Phase failure Note1)	•	•	•	•	•	•	•	•
	Lock/Stall	•	•	•		•	•	•	•
	Phase unbalance	_	•	_	•	_	•	_	•
	Reverse phase	_	●(3PR)	_	●(3SR)	_	●(3TR)	—	●(3SR)
Current setting ran	ige(A)	4~20, 8~40						16~80	
Operating time cha	aracteristics	Inverse time of	characteristics						
Time setting	Inverse time	0~30 sec							
(sec)	Definite D-time	0.2~60 sec (0	GMP40-2PD)						
	O-time	5sec (Fixed)	(GMP40-2PD)						
	Reset time	Manual reset	(Auto Reset type	e : GMP□-A)					
Tolerance	Current	±5%							
	Time	±5% (or±0.	5 sec)						
Control power	Voltage	AC 100~260\	/, 50/60Hz						
Aux. contact	Contact Note2)	2SPST (1a1b)						
	Ratings	3A/250VAC F	Resistive load						
	Operate	(95 北 96 Clo	se) (97	r⊣⊦ 98 Open)					
Insulation resistan	се	Min 100MΩ at	500Vdc						
Surge endurance (IEC 61000-4-5)	5kV Apply the	e standard wave						
Fast transient burs	st (IEC 61000-4-4)	2kV							
Environment	Operation	-25~70 ℃							
Temperature	Storage	-30~80 ℃							
	Relative humidity	30~90%RH (No freezing)						
Trip indicator		Red LED	Red/Green LED	Red LED	Red/Green LED	Red LED	Red/Green LED	Red LED	2Red LEDs
Dimension(mm)	W×H×D	53×78×87.5	5	53×68×87.	5	53×38×87.	5	89×77.5×9	7.4
Mounting type		Direct mount Metasol MC (I	onto a VIC-32a, 40a)	Separate mo	unt (Screw or Dir	n-rail)			
Certification		UL, cUL, CE	(Except GMP-PI	D, PA, SA type)				

Note) 1. When it is 2CT modle, only two-phase protection is available 2. When power applied Aux. Contact operate

Specification

GMP Series

Ratings							
M	odel	GMP60T	GMP60-TE	GMP60-TD	GMP60-TDa	GMP60-3T(R)	GMP60-3TZ(R) GMP60-3TN(R)
Туре		Tunn	el type	Tunne	type	Tunnel type	Tunnel type
No. of CT		20	Т	2	CT	3CT	3CT
Protection	Overcurrent				•	•	•
	Phase failure				•	•	•
	Lock/Stall				•	•	•
	Phase unbalance	-	-	—		•	•
	Reverse phase	-	_	—		●(R Type)	●(R Type)
	Ground fault Note1)	-	_		_	_	•
Current setting ran	ige (A)	0.5~6, 3~30, 5~60		0.5~60		0.5~60	0.5~60
Operating time cha	aracteristics	Definite		De	finite	Definite	Definite
Time setting	D time	0.2~3	0 sec	1~6	60 sec	0.2~60 sec	0.2~60 sec
(sec)	O time	0.2~15 sec	5 sec (Fixed)	0.5~	30 sec	0.2~15 sec	3 sec (Fixed)
	A time (Reset)	—	0.2~120 Note4)	—	1~20 min	—	_
Tolerance		Current ±5%	Time \pm 5% (or	±5 sec)			
Control power	Voltage Note3)	AC 110V/220	(±10%) Note3)	AC 110V or 2	20V (±10%)	AC 100V~260V	
	Frequency	50/60Hz					
Aux. contact	Contact	1SPDT: 1c (N	Note 2)	2SPST (1a1b)		
	Ratings	1A/250VAC F	Resistive load	3A/250VAC F	Resistive load		
Insulation resistant	се	Min 100MΩ at	500Vdc				
Surge endurance (IEC 61000-4-5)	5kV Apply the	e standard wave				
Fast transient burs	st (IEC 61000-4-4)	2kV					
Environment	Operation	-25~70 ℃					
Temperature	Storage	-30~80 ℃					
	Relative humidity	30~90% RH	(No freezing)				
Trip indicator		Red LED		7 Segment		Red/Green×2-Color LED	Red/Green×2-Color LED, Red LED
Dimension(mm)	W×H×D	72×67×69		75×72.8×47	7	94.6×95×97	94.6×95×97
Mounting type		Separate mount (Screw or Din-rail)					
Certification		UL, cUL, CE				_	
Note) 1. 3TZ(R): Zero sequ 2. 1c(N): No volt rele 3. GMP60T/TE: AC 4. GMP60TA: Auto I	uence CT type, 3TN(R): Resease contact type [1c(R), No 24V, 48V, 380V or 480V 50 Reset type	sidual curcuit on-fail-safe operatio /60Hz types a optio	n contact type is opti n	nal]			

Specification **DMP/IMP Series**

Rat	tings					- 1283		State Stat
М	lodel	DMP S/SZ/SI	DMP⊡-Sa/SZa	DMP T/TZ/TI	DMP⊡-Ta/TZa	IMP-C-NO	IMP-C-A420	IMP-C-M485
Wiring		Screv	v type	Tunne	el type		Tunnel type	
Panel mount		Unit or Extension	Note1)			Unit or Exte	ension	
Operation time		Inverse/Definite				Thermal Inv	verse/Inverse/	/Definite
Protection	Over current	According to the s	etting time			According t	o the setting t	ime
	Phase failure	3 sec				1.5 sec		
	Reverse phase	Within 0.1 sec				Within 0.1 s	sec	
	Lock/Stall	Within 0.5 sec				Within 0.5 s	sec	
	Phase unbalance	5 sec				3 sec		
	Under current	3 sec				3 sec		
	Ground fault	Within 0.05~1 sec	. (DMP⊡-Z/Za)			Within 0.05~1 sec Note2)		
	Short circuit	Within 50ms (DM	P□-I)			Within 50ms		
Alarm		Variable (60~110	% of the setting currer	nt)		Variable (60-	~110% of the s	etting current)
Current setting rai	nge (A)	6: 0.5~6A, 36 : 3~	36A, 60: 5~60A			0.5~100		
Time setting	Definite D time	0~60 sec				1~200 sec		
(sec)	O time	0~30 sec				1~60 sec		
	Inverse time	0~60 sec				1~60 sec		
	A time (Reset)	Manual reset				Manual res	et/Autometic	
Tolerance	Current	±5%				±5%		
	Time	±5% (or±0.5 se	c)			±5% (or±	0.5 sec)	
Operating power	Voltage	AC 110V or 220V	(±10%), 50/60Hz			AC/DC 85~2	45V, AC/DC 24	~36V (50/60Hz)
Aux. contact		2a, 2b, 1a1b				OL: 1a1b, A	AL: 1a	
Insulation resistar	nce	Over DC 500V 10	OMΩ			Over DC 50	00V 100MΩ	
Surge impulse vol	Itage (IEC 61000-4-5)	5kV				5kV		
Fast transient burs	st (IEC 61000-4-4)	2kV				2kV		
Environment	Operation	-25~70 ℃				-25~70 ℃		
Temperature	Storage	-30~80 ℃				-30~80 ℃		
	Relative humidity	30~90% RH (No 1	reezing)			30~90% RI	H (No freezing	3)
Display	7-Segment	Cause of a fault A	mpere meter			3 phase cu	rrent, cause o	of a fault
	Bar-Graph	60~110% of real I	oad current			60~110% c	of real load cur	rrent
Mounting type		35mm Din-rail/Pa	nel			35mm Din-	rail/Panel	
Certification		UL, cUL, CE (Exc	ept DMP36 type)			CE		

Note) 1. In extension type, the digital EMPR is calibrated with combining the display past and main body so, please cautious not to combine the display part and main body with different part No. 2. Zero current sensing by zero sequencee CT and Residual circuit. 3. DMP-a Type option : Operating time, Fault event save, 3phase current Ampere meter Function

Inverse time characteristics

GMP22/40 Type





Participation

- Wide and adjustable current range
- Adjustable trip time (trip class 5-30)
- Designed suitable for use with contactors
- Directly mountable on the Metasol contactors (Pin type) Separate mount versions are also available
- Separately mountable on 35mm DIN rail or with screws
- 1NO+1NC trip contacts
- Manual reset as standard (Automatic reset optional)

Front face configuration









<u>Certificate</u> CE, ULcUL

Extended protective functions

Types (GMP22/40-□)		-2P, -2T, -2S	-3P, -3T, -3S	-3PR, -3TR, -3SR
Number of sensors		2CT	3CT	3CT
	Overcurrent	\checkmark	\checkmark	\checkmark
	Phase failure	\checkmark	\checkmark	\checkmark
Functions	Locked rotor	\checkmark	\checkmark	\checkmark
	Phase unbalance		\checkmark	\checkmark
	Reverse phase			\checkmark

Technical information

Relay control voltage	100 to 260V AC 50/60Hz		
Auvillance contect	3A/250VAC at resistive load		
Auxiliary contact	1NO (97-98) + 1NC (95-96)		
Satting tolerance	Current \pm 5%		
Setting tolerance	Time \pm 5% (or \pm 0.5sec)		
Insulation resistance	Min 100№ at 500V DC		
Impulse withstand voltage	5kV (IEC 61000-4-5)		
Fast transient burst	2kV (IEC 61000-4-4)		
Ambient termeneture	-25 to 70 °C for operation		
Ambient temperature	-30 to 80 ℃ for storage		
Humidity	30 to 90% RH		

Inverse time characteristics GMP22/40 Type



To mount on 35mm DIN rail



Cable connection part can be modified between screw connection and passing CT hole

Mount/Connection	Sensor	Setting range	Catalog No.
Directly on a contactor	2-sensor	0.3 - 1.5A	GMP22 - 2P · 1.5
	(2 CT)	1 - 5A	GMP22 - 2P · 5
		4.4 - 22A	GMP22 - 2P · 22
_	3-sensor	0.3 - 1.5A	GMP22 - 3P · 1.5
	(3 CT)	1 - 5A	GMP22 - 3P · 5
_		4.4 - 22A	GMP22 - 3P · 22
	3-sensor	0.3 - 1.5A	GMP22 - 3PR · 1.5
	Reverse phase	1 - 5A	GMP22 - 3PR · 5
	detection	4.4 - 22A	GMP22 - 3PR · 22
Separate mount	2-sensor	0.3 - 1.5A	GMP22 - 2S · 1.5
	(2 CT)	1 - 5A	GMP22 - 2S · 5
Cable connection		4.4 - 22A	GMP22 - 2S · 22
with a screw	3-sensor	0.3 - 1.5A	GMP22 - 3S · 1.5
	(3 CT)	1 - 5A	GMP22 - 3S · 5
_		4.4 - 22A	GMP22 - 3S · 22
	3-sensor	0.3 - 1.5A	GMP22 - 3SR · 1.5
	Reverse phase	1 - 5A	GMP22 - 3SR · 5
	detection	4.4 - 22A	GMP22 - 3SR · 22
Separate mount	2-sensor	0.3 - 1.5A	GMP22 - 2T · 1.5
	(2 CT)	1 - 5A	GMP22 - 2T · 5
Connection		4.4 - 22A	GMP22 - 2T · 22
without a screw	3-sensor	0.3 - 1.5A	GMP22 - 3T · 1.5
- cables pass	(3 CT)	1 - 5A	GMP22 - 3T · 5
through CT holes		4.4 - 22A	GMP22 - 3T · 22
	3-sensor	0.3 - 1.5A	GMP22 - 3TR · 1.5
	Reverse phase	1 - 5A	GMP22 - 3TR · 5
	detection	4.4 - 22A	GMP22 - 3TR 22

Selection (GMP40 Type)

Mount/Connection	Sensor	Setting range	Catalog No.
Directly on a contactor	2-sensor	4 - 20A	GMP40-2P · 20
	(2 CT)	8 - 40A	GMP40-2P · 40
	3-sensor	4 - 20A	GMP40-3P · 20
	(3 CT)	8 - 40A	GMP40-3P · 40
	3-sensor	4 - 20A	GMP40-3PR · 20
	Reverse phase	8 - 40A	GMP40-3PR · 40
	detection		
Separate mount	2-sensor	4 - 20A	GMP40-2S · 20
	(2 CT)	8 - 40A	GMP40-2S · 40
Cable connection	3-sensor	4 - 20A	GMP40-3S · 20
with a screw	(3 CT)	8 - 40A	GMP40-3S · 40
	3-sensor	4 - 20A	GMP40-3SR · 20
	Reverse phase	8 - 40A	GMP40-3SR · 40
	detection		
Separate mount	2-sensor	4 - 20A	GMP40-2T · 20
	(2 CT)	8 - 40A	GMP40-2T · 40
Connection	3-sensor	4 - 20A	GMP40-3T · 20
without a screw	(3 CT)	8 - 40A	GMP40-3T · 40
- cables pass	3-sensor	4 - 20A	GMP40-3TR · 20
through CT holes	Reverse phase	8 - 40A	GMP40-3TR · 40
	datastian		







Selection (GMP22 Type)

Definite time characteristics

GMP60-T(E) Type



2 Description

- Small size, economical
- Delay time setting in starting and operation
- Over current, phase failure protection
- Definite time characteristics
- Wide current setting range
- Screw or Din-rail mounting

Extended protective functions

Types		GMP60-T	GMP60-TE	GMP60-TA
Number of sensors		2CT	2CT	2CT
Functions	Overcurrent	\checkmark	\checkmark	\checkmark
	Phase failure Note)	\checkmark	\checkmark	\checkmark
	Locked rotor	\checkmark	\checkmark	\checkmark
	Auto reset	-	-	\checkmark

* Only two-phase protection is available.

Ratings (Tunnel type)

Model		GMP-60T	GMP-60TE	GMP-60TA	
Туре		Tunnel type			
No. of CT		2			
Current se	etting range (A)	0.5~6, 3~30, 5~60			
Operating time	characteristics	Definite time characteristics			
Time cotting	Starting time	0~30			
(coo)	Operating time	0~15	5	5	
(Sec)	Reset time	Manual reset		0~120	
Allowable	Current	±5%			
error	Time	\pm 5% (or \pm 0.5 sec)			
Control power	Voltage	220V (AC 24V/48V/110V/380V(440)) ^{Note2)} , AC 180~480V			
Control power	Frequency	50/60Hz			
	Contact Note3)	1SPDT (1c)			
Aux. s/w	Ratings	5A 250Vac, resistive load			
	Operation	95			
Insulation resistance		Min. 50MΩ at 500Vdc			
Surge insurance	e (IEC 61000-4-5)	5kV			
Fast transient bur	st (IEC 61000-4-4)	2kV			
Environment Operation		-25~70°C			
Temperature Storage		-50~80℃			
Relative humidity		46~85 RH (No freezing)			
Trip indicator		LED			
Dimension (mm) $W \times H \times D$		72×63×69			
Mounting type		Separate mount (Screw & Din-rail)			
Certification		UL, cUL, CE -			

Note) 1. Under phase failure condition over current flows. The EMPR tripped if it is over the setting over current

2. () are optional specifications

Tunnel type EMPR protects the current under 0.1A

If we increase the number of times of a wire pass through the CT (Tunnel), the EMPR can detect the lower current

No. of times to pass through	Current setting range
1	0.5~6
2	0.25~3
3	0.17~2
4	0.12~1.5



Large current over 60A can be applied through additional current transformers

Ampere meter function GMP60-TD(a) Type



2 Description

- Definte time characteristics
- Delay time setting in starting and operation
- Over current, phase failure protection
- Definite time characteristics
- Wide current setting range
- Screw or Din-rail mounting
- Display the causes of the fault and the values

Extended protective functions

Types		GMP60-TD	GMP60-TDa	
Number of sensors		2CT	2CT	
Functions	Overcurrent	\checkmark	\checkmark	
	Phase failure Note1)	\checkmark	\checkmark	
	Locked rotor	\checkmark	\checkmark	
	Under current	-	\checkmark	
	Auto reset	-	\checkmark	

* Only two-phase protection is available.

Ratings (Tunnel type)

Model		GMP60-TD	GMP60-TDa	
Туре		Tunnel type		
No. of CT		2		
Current setting range (A)		0.5~60		
Operating time characteristics		Definite time characteristics		
Time cotting	Delay time	1~60		
(coo)	Operating time	0.5~30		
(Sec)	Reset time	Manual reset	1~20min	
Allowable	Current	±5%		
error	Time	$\pm5\%$ (or ±0.5 sec)		
Control power	Voltage	AC 110/220V (±10%)		
Control power	Frequency	50/60Hz		
	Contact Note2)	2SPST (1a1b)		
Aux. s/w	Ratings	5A 250Vac, resistive load		
	Operation	95 ⁺ / ⁺ 96close 97 ⁺ /- 98open		
Insulation resist	tance	Min. 50MQ at 500Vdc		
Surge insurance	e (IEC 61000-4-5)	5kV		
Fast transient bur	st (IEC 61000-4-4)	2kV		
Environment	Operation -25~70 °C			
Temperature Storage		-50~80 °C		
Relative humidity		46~85 RH (No freezing)		
Trip indicator		7-Segment		
Dimension (mm) $W \times H \times D$		72×63×69		
Mounting type		Separate mount (Screw & Din-rail)		

Note) 1. Under phase failure condition over current flows. The EMPR tripped if it is over the setting over current 2. When power applied the Aux. contact operate

Tunnel type EMPR protects the current under 0.1A

If we increase the number of times of a wire pass through the CT (Tunnel), the EMPR can detect the lower current

No. of times to pass through	Current setting range	Current Ratio	
1	0.5~6	1	
2	0.25~3	0.5	
4	0.12~1.5	0.25	

Definite time characteristics with 3CT

GMP60-3T(R) Type



GMP60-3T GMP60-3TR



Terminal Lug

Large current over 60A can be applied through additional current transformers

2 Description

- Cable connecting through CT holes (option: with screw)
- Auxiliary contact: 2SPST (1a1b at energization)
- Wide and adjustable current range (0.5~60A)
- D-time: 0.2~60 sec. / O-time: 0.2~15 sec.
- Control voltage: AC100~245V 50/60Hz
- Manual (electrical) reset as standard
- Applicable to inverter at the secondary circuit (except GMP60-3TR)

Extended protective functions

Types	GMP60-3T	GMP60-3TR	
per of sensors	3CT	ЗСТ	
Overcurrent	\checkmark	\checkmark	
Phase failure	\checkmark	\checkmark	
Locked rotor	\checkmark	×	
Phase unbalance	\checkmark	×	
Reverse phase	-	×	
e last fault cause	\checkmark	\checkmark	
	Types Der of sensors Overcurrent Phase failure Locked rotor Phase unbalance Reverse phase e last fault cause	TypesGMP60-3Tper of sensors3CTOvercurrent✓Phase failure✓Locked rotor✓Phase unbalance✓Reverse phase-e last fault cause✓	

Selection			
Mount/Connection	Optional function	Setting range	Catalog No.
· Separate mount	None	0.5 - 60A	GMP60-3T
Cable Connection			
through CT holes	Reverse phase	0.5 - 60A	GMP60-3TR

Technical information

Mounting	On 35mm rail or panel with screws
	Current \pm 5%
Setting tolerance	Time \pm 5% (or \pm 0.5sec)
Frequency	50/60Hz
Auxiliary contact rating	5A/250VAC at resistive load
Insulation resistance	Min 100MQ at 500V DC
Surge insurance	5kV (IEC 61000-4-5)
Fast transient burst	2kV (IEC 61000-4-4)
Amhianttannaustura	-25 to 70°C for operation
Amplent temperature	-30 to 80 °C for storage
Humidity	30 to 90% RH
Operating indication	Red/Green 2-color LED, Red LED
Standard	IEC60947-1

For ground fault current protection

GMP60-3TZ(R), 3TN(R) Type



GMP60-3TZ, 3TZR GMP60-3TN, 3TNR



Terminal Lug

2 Description

- Cable connecting through CT holes
- Auxiliary contact: 2SPST (1a1b at energization)
- Wide and adjustable current range (0.5~60A)
- Definite time characteristics
- D-time: 0.2~60sec. / O-time: 3sec.
- With 3 sensors (CT)
- Control voltage: AC100~245V (50/60Hz)

Extended protective functions

	· · · · · · · · · · · · · · · · · · ·
Number of sensors 3CT	ЗСТ
Overcurrent V	\checkmark
Phase failure V	\checkmark
Protective Ground fault	\checkmark
functions Locked rotor	✓
Phase unbalance V	✓
Reverse phase -	✓
Storing the last fault cause	✓

Selection

ound fault current	Optional function	Setting range	Catalog No.
ro phase current			
1~2.5A)	None	0.5 - 60A	GMP60-3TZ
CT required			
	Reverse phase	0.5 - 60A	GMP60-3TZR
esidual current			
5~6A)	None	0.5 - 60A	GMP60-3TN
	Reverse phase	0.5 - 60A	GMP60-3TNR
	sidual current ST required Sidual current S-6A)	None I~2.5A) None CT required Reverse phase sidual current 5~6A) None Reverse phase	None 0.5 - 60A I~2.5A) None 0.5 - 60A CT required Reverse phase 0.5 - 60A Sidual current 56A) None 0.5 - 60A Reverse phase 0.5 - 60A

Note) Use ZCT for EMPR, 100mA/40 ~ 55mV

Technical information

Mounting	On 35mm rail or panel with screws
	Current \pm 5%
Setting tolerance	Time \pm 5% (or \pm 0.5sec)
Frequency	50/60Hz
Auxiliary contact rating	5A/250VAC at resistive load
Insulation resistance	Min 100MQ at 500V DC
Surge insurance	5kV (IEC 61000-4-5)
Fast transient burst	2kV (IEC 61000-4-4)
Ambienttemmensture	-25 to 70°C for operation
Amplent temperature	-30 to 80 °C for storage
Humidity	30 to 90% RH
Operating indication	Red/Green 2-color LED, Red LED
Standard	IEC 61000, KEMC 1120

Inverse time characteristics

GMP80 Type



2 Description

- Wide and adjustable current range
- Adjustable trip time (trip class 5-30)
- Separately mountable on 35mm DIN rail or with screws
- 1NO+1NC trip contacts
- Manual reset as standard (Automatic reset optional: GMP80-2SA)

Front face configuration



Extended protective functions

Types (GMP80- w)		2S	2SA	3S	3SR
Number of sensors		2CT	2CT	3CT	3CT
Functions	Overcurrent	\checkmark	\checkmark	\checkmark	\checkmark
	Phase loss	\checkmark	\checkmark	\checkmark	\checkmark
	Locked rotor	\checkmark	\checkmark	\checkmark	\checkmark
	Phase unbalance	-	-	\checkmark	\checkmark
	Reverse phase	-	-	-	\checkmark
	Auto reset	-	\checkmark	-	-

Selection

Mount/Connection	Sensor	Setting range	Catalog No.
Separate mount	2-sensor	16 - 80A	GMP80-2S
	(2 CT)		
Cable connection	3-sensor	16 - 80A	GMP80-3S
with a screw	(3 CT)		
	3-sensor	16 - 80A	GMP80-3SR
	Reverse phase detection		

Technical information

Relay control voltage	100 to 260V AC 50/60Hz		
Auxiliary contact	3A/250VAC at resistive load		
	1NO (97-98) + 1NC (95-96) (When power applied)		
Setting tolerance	Current ± 5%		
	Time \pm 5% (or \pm 0.5sec)		
Insulation resistance	Min 100M2 at 500V DC		
Surge insurance	5kV (IEC 61000-4-5)		
Fast transient burst	2kV (IEC 61000-4-4)		
Ambient temperature	-25 to 70°C for operation		
	-30 to 80 °C for storage		
Humidity	30 to 90% RH		

<u>Certificate</u> CE, ULcUL

۲		3	
EMPR	G	MP80-3S	LS
TEST/ RESET O.L	FAULT	32, 49 16	0. 0. 0. 0. 0. 0. 0. 0. 0. 0. 0. 0. 0. 0
			95 - # - 96

Characteristics DMP Series

DMP-S/SZ/SI, T/TZ/TI Type







Extention type (with cable)

· Unit type or extension type is available

- Extension type:Remotely mounts the display unit on the panel surface
- Ampere meter function: current and setting value by press the display button
- · Select the inverse time or definite time
- · Display the causes of the fault and the values

Protect function

Over current	Depend on setting time	Selectable the inverse/definite
Phase failure	Within 3seconds	Over 70% of the rate of unbalance
Phase unbalance	Within 5seconds	Over 50% of the rate of unbalance
Reverse phase	Within 0.1seconds	Function enable
Stall	Within 5seconds	Over 180% of the setting current
Lock	Within 0.5seconds	Setting 200~900% of rated current
Under current	Within 3seconds	Setting 30~70% of rated current
Ground fault Note)	Selectable 0.05~1.0seconds	Grounded current setting by dip s/w (100~2500mA)
Short circuit	Within 50ms	300~1800% of rated current

Note) Lock protection is operated after setting D-time in case of definite time type

Function selection

FUNC	Sel	Description		
1. CHA	Inv/dEF	Operating characteristics setting (Inverse/definite time type)		
2. dEF Note1)	0~30 (S)	Setting the operating time (In definite type)		
3. r.P	oFF/on	Reverse phase enable		
4. Und	oFF/30~70 (%)	Under current enable and setting		
5. Alt	oFF/60~110 (%)	Alerting enable and setting (DMP-S, T type)		
5. g-F	oFF/0.05~1.0 (S)	Ground fault enable and setting (DMP-Z type)		
5. Sho	oFF/300~1800 (%)	Short current enabling and setting (DMP-I type)		
6. Stl	oFF/on	Stall enable		
7. Loc	oFF/200~900 (%)	Lock enable and setting		
8. Ct	1~120	CT ratio setting		
9. P.F	on/oFF	Phase fault enable		
A. gFd Note2)	oFF/on	Setting delay of ground fault (DMP-Z type)		
b. StA	0~120	Operating time setting by month (DMP-a type)		
c. StH	10~730	Operating time setting by hour (DMP-a type)		
d. tAH	A000,000.0	Displaying total operating time (month, hour) (DMP-a type)		
E. rAH	A000,000.0	Displaying operating time (month, hour) (DMP-a type)		
Sto	Sto	Store		

Note) 1.[2.dEF] is only displayed when dEF is selected in a 1.CHA mode 2. Functions for A to E are available for only DMP-a type.

Ratings						
Model			DMP⊡-S/Sa, T/Ta, SI	DMP -SZ/SZa/SI, TZ/TZa/TI		
Туре	Type Wiring method		S: Screv	S: Screw, T: Tunnel		
	Panel mou	ınt	Unit or	Extension		
Operating char	acteristics		Inverse/	definite type		
Alerting function	n		Variable be	tween 60 and 110%		
Current range (A)		06: 0.5~6, 36	: 3~36, 60: 5~60		
Setting time	Definite	Delay (D-T)	0~60	seconds		
		Operating (O-T)	0~30seconds			
	Inverse		0~60	0~60seconds		
	Reset type)	Man	Manual reset		
Operating	voltage		AC 110V/220V (±10%)			
voltage	Frequency	/	50/60Hz			
	ZCT input	(07-08)	200mA/110mV (ZCT) [30Ø, 50Ø, 65Ø, 80Ø]			
Aux. contacts			3A/250Vac	c resistive load		
Indicate	7-segmer	ıt	3-phase current	value, fault cause		
	Bar-LED a	rrays	Load ratio	Load ratio (60~110%)		
Mounting		35mm Din-rail/Panel				
Certification			UL, cUL, CE (Except DMP36 type)			

Characteristics IMP Series

IMP-C Type



Extention type (with cable)

MODBUS RS-485 Communication or 4~20mA analogue output

- 3 phase ampere meter function: Check the 3 phase current and setting value by press the display button
- · Select the Thermal inverse/inverse time or definite time
- Easy to operate: Set the most function by the operation button and knob
- Display the causes of the fault and the values
- Adjustable wide current range (0.5~100A)

Protect function

Over current	Depend on setting time	Selectable the inverse/definite
Phase failure	Within 1.5seconds	Over 70% of the rate of unbalance
Phase unbalance	Within 3seconds	10~70% of the rate of unbalance
Reverse phase	Within 0.1seconds	Function enable
Stall	Within 3seconds	setting 150~500% of rated current
Lock Note1)	Within 0.5seconds	Setting 200~800% of rated current
Under current	Within 3seconds	Setting 30~90% of rated current
	Selectable 0.05,	gF: 0.03/0.05/0.1~3A
Ground fault Note2)	0.1~1.0seconds	gn: 20~500% of the FLC min

Note) 1. Lock protection is operated after setting D-time in case of definite time selected. 2. 12. gF Zero sequence CT, 13. gn Residual circuit sensing.

Setting Menu (A Group)

Menu	Setting Value	Item	Default Value
1.CHA	dEF/th/n-th	Operation Characteristics (Definite Time / Heat Accumulation Inverse Time /Inverse Time)	n-th
2.0-t	1~60s	Operation Time (sec)	60
3.d-t	1~200s	Operation Delay (sec)	In chase of dEF
4.r-C	0.5~10A/5~100A	Rated Current	Max.
5.Ctr	0.25, 0.5, 1~200	CT Ratio (4 times, twice, once)	1
6.Loc	OFF, 200~800%	Lock Protection (sec)	OFF
7.StL	OFF, 150~500%	Stall Protection (sec)	OFF
8.P-F	OFF/On	Open Phase	OFF
9.P-U	OFF, 10~70%	Unbalance Protection (%)	OFF
10.rP	OFF/On	Reverse Phase	OFF
11.UC	OFF, 30~90%	Low Current Protection (%)	OFF
12.gF	0FF, 0.03, 0.05/0.1~3A	Ground Fault Operation Current (Zero-Phase-Sequence Current) (A)	OFF
13.gn	OFF, 20~500% (FLCmin)	Ground Fault Operation Current (Post-Arc Current) (FLCmin)	OFF
14.gt	0.05, 0.1~1.0s	Ground Fault Operation Time (Current)	-
15.gd	On/OFF	Ground Fault Delay During Start	ON
16.IC	OFF, 500~1000%	Instantaneous Protection (%)	OFF
17.AL	I-tp,I- AL, ALo, U-C, OrH	07-08 setting	l-tp
18.Ar	On,60~110% On,60 0%	Alert setting	Only "ALo"
19.cS	1a1b, 2a, 2b	Contact setting	1a1b

Setting Menu (B Group)

	Menu	u Setting Value Item		Default Value
	1.E-r On/OFF		Electric Recovery	On
	2.A-r	OFF, 1~20 min	Automatic Recovery (Minute)	OFF
	3.r-t	Hour/Minute	Operation Time	Time Check
	4.Srt	OFF, 1~8760Hour	Operation Time Setup (Hour)	-
Î	5.s-d	2009/01.01/00:00	YY/MM/DD/ HH:MM	-
1	6.Trt	Day/hour:minute	Total Operation Time	Time Check
1	A.t-d	0.5~10/5~100A	20mA Output Setup	A420
	A.Adr	1~247	Communication Address	
b.bps 96/192/384 c.S-P On/OFF		96/192/384	Communication Speed M485 Mo	
		On/OFF	SWAP	

Note) 1. When the power is supplied first or is resupplied after a power failure, must set up the date (5.S-d).2. Automatic recovery is only possible in case of an excess

current trip.

Note) 1. When the rated current S/W is 100A, the CT ratio is not displayed. 2. Some menus are not displayed if relevant functions are not available.

Ratings

Model			IMP-C-NO, M485, A420	
Туре	Wiring method		Tunnel	
	Panel mo	unt	Unit or Extension	
Operating charac	cteristics		defin/TH-Inv./n-TH	
Alerting function			Variable between 60 and 110%	
Current range (A)		0.5~100	
Setting time	Definite	Delay (D-T)	1~200seconds	
		Operating (O-T)	0~30seconds	
	Inverse/TH-Inverse time		0~60seconds	
	Reset type	9	Manual reset	
Operating	Operating Control power [A1(+), A2(-)]		AC 85~245V, AC 24~36V (50/60Hz)	
ZCT input (Z1, Z2	2)		200mA/110mV (ZCT) [30Ø, 50Ø, 65Ø, 80Ø]	
Aux. contacts (2a AL (07-08)	a, 2b, 1a1b)	OL, GR 2-SPST (95~98)	5A/250Vac resistive load	
Indicate	7-segmer	nt	3-phase current value, fault cause 5point	
	Bar-LED a	rrays	Load ratio (60~110%)	
Mounting			35mm Din-rail/Panel	
Communication			A420: Analog, M485: Modbus	
Certification			CE	

1. Check the rated voltage and apply the control power to A1 and A2 terminal

2. Check the TEST/RESET button

- 1) When you press the 'Test/Reset' button, the O.L LED is turned on and the EMPR is tripped 2) When you press the 'Test/Reset' button under the EMPR is tripped, the O.L LED is turned
 - off and the EMPR is reset
- 3) Auto reset function: When it is tripped by the over current, it is reset after 1 Min.(Optional)

3. Set the operating time

- The operating time is set on the base of 600% of the rated current in the characteristic curve
 - 1) Set the operating time by considering the operating time and start current according to the types of the load
 - If the time knob is set to 10sec, the EMPR is tripped when the start current (600% of the rated current) is applied for 10sec

Caution) The EMPR with inverse time characteristics can be tripped to protect the motor when the motor is started a few times continuously When a motor is frequently changing the rotating direction (forward and reverse), set the operating time longer For the crane and hoist use, select the EMPR with definite time characteristics

4. Set the operating current

Set the current by considering the rated current of a motor to protect from the over current 1) Check the rated current of a motor is within the current setting range of an EMPR

- 2) Set the 'RC' (Rated current) knob to the maximum value and then start a motor
- 3) Under normal motor operation, rotate the 'RC' knob to the counterclockwise until the 'O.L' LED flickers The current at this point in the 100% current rating under real load
- 4) At this point, rotate the 'RC' knob to the clockwise until the 'O.L' LED turned off. Ex) When the 'O.L' LED flickering at 20A, the setting current will be 22A(=20x1.1) Note) The brackets for connection is offered standard

5. Check status of operation by LED

- 1) In case of overcurrent
 - If there will be an overcurrent during motor operation, the red color of LED will flicker at 0.4 second intervals. After tripping because of overcurrent, the red color of LED will light up.
- In case of phase failure
 If there will be a phase failure in three phase load, it will be tripped within 3 seconds.

 Note) 2CT EMPR can protect motor from R or T phase failure.
- 3) In case of phase unbalance
- If phase unbalance rate is over 50%, FAULT LED will flicker 0.4 second intervals.
- 4) In case of Reverse phase

Red & green color LED will flicker alternately.

Condition		Condition	LED Status	LED Diagram	Remark
Ope	Normal		LED OFF		
rating s		Over current	0.4 Second intervals		
tatus	Phase unbalance (30~50%)		0.4 Second intervals		GMP 80-3S/3SR model, only red color LED will flicker.
	Over current		O.L LED light up		
	Phase failure	R	1 time for 3 seconds		
Tripped status		S	2 time for 3 seconds		GMP 80-3S/3SR model, O.L LED will light up and also FAULT LED will flicker.
	(3CT)	т	2 time for 3 seconds		
	Phase failure (2CT)		Red LED light up for 0.9 sec LED goes off for 0.1 sec	<u>+ 0.9 + 10.1</u>	
	Reverse phase (3CT)		Red & Green color LED flicker alternately		GMP 80-3S/3SR model, Red/Green LED will flicker.

Note) There are two red color LEDs for O.L (Overload) & Fault in the model of GMP80-3S/SR

Setting method

GMP Series Definite time

X Tunnel type mounting

1. Check the Test/Reset button operation

- 1) Check if the wiring is correct (Refer to the wiring diagram)
- 2) Set the 'D-Time' and 'O-Time'' knob to the min. ratings3) When the 'Test' button is pressed under tripped condition,
- the 'O.L' LED is turned off

Note) In operation, even though you press the 'Test/Reset' button, the EMPR do not trip

2. Set the operating time

D-time (Delay time): 0~30 sec

The motor starting current, which flows when the motor is starting, is generally 600% of the rated current. It is the time during which the EMPR do not operated by over-current during the starting time

- 1) Set the delay time by use of the 'D-time' knob
- 2) In case you do not know the delay time, start the motor by setting the 'D-time' knob to the max. position and after checking the time during which the staring current become stable, set the D-time (In general, the setting time is 3~5 seconds)

The operating time is the time during which the EMPR tripped by the over-current. The EMPR is tripped after the selected operation time

- 1) Set the operation time by the 'O-time' knob
- 2) If you set the 'O-time' to the min value, the EMPR is tripped at once

Note) Generally set it to 4~6 seconds

3. Set the operating current

- 1) Start the motor by setting the 'RC' knob to the maximum position
- 2) Under operating condition, rotate the 'RC' knob to the counterclockwise until the 'O.L' LED turned on & off. The current at this point is the value (100%) under real load condition
- 3) Rotate the 'RC' knob to the clock-wise until the 'O.L' LED turned off. Ex) When the 'O.L' LED flickering at 20A, the setting current will be 22A(=20x1.1)





Definite time characteristics curve



(ex: When the 'O.L' LED settings at 21A, the setting current will be 23A (=21*1.1))

Condition		Red O.L LED	Note
Operation normal	Off		
Overcurrent	Flicker		
Trip over-current	On		The EMPR is tripped

4. Check the LED condition when operation

1) Over-current

- The EMPR is not tripped during the D-time under over-current but the O.L LED turned on and off to indicate that the over-current flows
- If the EMPR is tripped after D-time the O.L LED turned on



Function & Setting menu

- 1) Automatic reset setting will work in the event of overcurrent trip
- 2) Func. A and b are to check the elapse time, not for setting
- 3) Undercurrent protection function will work at the current flow more than 0.4A
- 4) In case of changing the rating DIP S/W FUNC #1 should be changed accordingly
- 5) Function setting is allowable at TEST mode
 - Turn off the power before changing a current type switch, and then be sure to adjust the current in the menu

Setting Menu

FUNC	SEL	Description	Remarks
*I.EE4	68/608	Current type selection	Set the same with rated current S/W
20-E	0.5/1~30(SEC)	Trip time setting	-
3.d-E	1~60/1(SEC)	Time delay setting	-
\ \ \ \ - [0.5~6.0/5~60	Rated current setting	-
5.Etr	0.25/0.5/1~120	Current ratio setting	-
\$ 6,P - F	oFF/on	Phase loss enable	-
₹ ႢIJ- Ը	₀FF/30~70(%)	Undercurrent setting	For TDa model only
88-r	₀FF/I~20(MIN)	Automatic reset setting	For TDa model only
Sr E	oFF/10~8760	Operation hour setting	For TDa model only
₿₽₽-₽	-	Total running hour check	For TDa model only
<u>ה-ר</u>	-	Running hour check	For TDa model only
) Sto	-	Store	-

Note) 1. If operation hour set at (356) is elapsed 260 is displayed and the relay operates normally. (There is no additional relay output) 2. How to check 260 and 260

Display How to check

 Press SEL
 Day displayed
 Press SEL
 Hour, Min displayed

 Press SEL
 Operation hour displayed
 Press SEL
 Day displayed

 Press SEL
 Min displayed
 Press SEL
 Day displayed
 Ert

r-t

 When power is OFF the data in unit of minute is deleted at
 Operation hour at
 is the total running hour before the motor is oFF and displayed in Day, Hour and Min. When motor is OFF the data is deleted.

Fault status configuration

Protection	FND	Description	Remarks
Over current	0 - L	More than set current : Within the set time	
Undercurrent	U-C	Lower than the undercurrent set ratio : Within 3S	GMP60TDa
Phase Loss	PF - r	Over 70% of the rate of unbalance : Within 3S	R Phase Loss
	PF-t	Over 70% of the rate of unbalance : Within 3S	T Phase Loss
LOCK	Loc	More than lock set current ratio : Within 1S	
Approaching Running Time OrH When Running time approaches at setting time		When Running time approaches at setting time	GMP60TDa

Note) When the 'FUN' Key and 'SEL' Key are pushed simultaneously, a last trip cause appears on the disply window.

Setting method

GMP60-3TZ(R) / 3TN(R) Type

Trip curve: definite time characteristics

- Protective function: overcurrent, locked rotor, phase loss, phaseun balance, ground fault (and phase reverse)
 - 1) Overcurrent: trip within 3 sec. after D-time at 105% or more
 - 2) Locked rotor: trip within 1 sec. after D-time at 300% or more
 - 3) Phase loss: trip within 3 sec. (phases unbalance rate over 70%)
 - 4) Phase unbalance: trip within 5 sec. (phases unbalance rate over 50%)
 - 5) Ground fault: trip within 0.5 sec. after D-time at over 110% or under 90% of set value
 - 6) phase reverse: trip within 1 sec. when any two phases out of three

• Overcurrent trip time

- 1) Time delay(D-time) setting: between 0.2-60 sec.
- 2) Trip time(O-time) setting: fixed at 3 sec.

Last fault cause data stored

- to display it press TEST/RESET button 2 times within 0.5 sec.
- PWR LED flicking in case of no fault

Note) In case of load less than minimum rating of EMPR make the number of penetrating through CT more than 2 times. If not, error may happen to phase loss .



- Note) 1.Make power off before changing the rated current with S/W ① 2.The setting range of RC (A) KNOB (ii) is recognized as 0.5 - 6A or 5 ~ 60According to the setting value of S/W ①. The value of the scale for RC (A) KNOB (ii) is 0.5, 1, 2, 3, 4, 5, 6 or 5, 10, 20, 30, 40, 50, 60(A)from the left.
 - 3. Last fault cause function indicates the LED status for the last TRIP.

Status of LED configuration

NO	Function	Setting	Description	Remark
1	6A/60A	Slide switch	Maximum rated current (6A/60A) setting	-
2	PWR.	Red LED	Lights up when power is ON	Blinking in the failure mode
3	FAULT	Red / Green LED	Overcurrent / unbalance in progress:	Red LED Green LED
(4)	GF	Red LED	Lights up after blinking in the event of ground fault	-
(5)	D-TIME (S)	KNOB	Delay time (0.2 to 60 sec.)	-
6	RC (A)	KNOB	Rated current setting: 0.5~6A/5~60A	-
		KNOD	Sensitivity current setting (0.1~2.5A)	Zero phase current detection type
() GR (A)		KINOB	Sensitivity current setting (0.5~6A)	Residual current detection type
(8)	TEST/RESET	BUTTON	TRIP / RESET alternately perform 1. Check relay contacts - displays fault cause 2. RESET	Pressing 2 times within 0.5 sec. the final failure cause is displayed
	ļ			

1. Check the operation of the Test/Reset button

- 1) Check the wiring method
- 2) Press the Test/Reset button and then test is displayed on the LED and the DMPR is tripped

3) Press the Test/Reset button again and then it is reset

Note) The Test/Reset is not available when a motor is rotating.



2. Shift the mode by pressing the FUNC key and then select the values by the Sel key

- 1) First shift to the test mode by press the "Test/Reset" button and then set the functions by press the "FUNC" button
- 2) Each time you press the"FUNC" button, the function mode switches from 1.CHA mode to Sto mode. When the mode that you want to change is displayed, push the "Sel" button to select the value you want. After you select the value, press the "FUNC" button to finish the settings and it displays the next mode
- 3) If no button is pressed in the selection mode, it remains in that mode
- 4) If you select the inverse time characteristics it skips the mode 2 (Definite O-time) and go to the mode 3 (Reverse phase)
- 5) Alt is the alert setting mode. It displays the load rate of the current setting value by the bar LED (60~110%)
 - If the current is higher than the setting value, the bar LED is switched on and off and the AL relay (07-08)
 - make close and open in 1sec interval unit the EMPR is tripped (Prealarm function)
 - If the 5. Alt mode is set to off, the AL relay make close after the EMPR is tripped (Normal open contact)
- 6) To finish the settings you have to press the "Sel" button in the Sto mode



Setting Menu

eening ii			
FUNC	Sel	Functions	Note
RK <u>J. I</u>	l nu/dEF	Inverse or definite time characteristics	Default is inverse time characteristics
735.5	0~30	Set the O-time (Definite time only)	For D-time setting, use the time knob
Å3. r.P	oFF/on	Reverse phases protection	Default is "Off"
}\U∩d	oFF/30~70(%)	Under current protection	Default is "Off" Note1)
\$ <u>5.81</u> 2	oFF/80~110(%)	Alarm function (With pre-alarm function)	Default is "Off" (DMP-S, T type)
\$ <u>5.</u> 9-F	oFF/0.05~1(58C)	Ground fault and Setting the operating time	Default is "Off" (DMP-Z type)
\$ <u>5.5ho</u>	oFF/300~1800(%)	Short current Protection enabling and setting	Default is "Off" (DMP-I type)
8.5EL	oFF/on	Stall function	Default is "Off"
- RLoc	oFF/200~900(%)	Lock function	Default is "Off"
8. CE	I~120	CT ratio	Default is 1:1 Note2) (DMP06 Modle)
8 <u>9</u> .2 - F	on/oFF	Phase failure	Default is "On"to store
8.9Fd	oFF/on	Setting delay of Ground Fault	Available for SZa/TZa
§b.5と8	0~120	Operating time setting (Month)	
<u>}כ.5</u> צא	10~730	Operating time setting (Hour)	
}d.⊱8H	8000,000.0	Displaying total operating time (Month, Hour)	DMPSa/Ta/Sza/Tza model
8 88	8000,000.0	Displaying operating time (Month, Hour)	
\$ 5εο	560	Store	Push the SEL button to store

Note) 1. Set the under current value from above 350mA

4. When using external CT, maximum primary current is 600A

Do not change the CT ratio in 36, 60 type
 When using DMP to loads over 60A, you should use DMP-06 and an external CT that secondary output is 5A

Setting method

DMP Series



3. Adjust the operating time by the time knob

- 1) Select the inverse time in the 1. CHA mode, the default operating time is 600% of the
- 2) The setting range of the operating time is 0~60sec. Set the time by considering the motor
- 3) When it is over the setting time, the EMPR operate in accord with the hot characteristics curve

Definite time characteristics

- 1) Select the definite in the 1. CHA mode, it is operated by the definite time characteristics
- 2) D-time means the time that delays the operating time when the motor is starting
- 3) The setting range of the operating time is 0~60sec. Set the time by considering the motor start time
- 4) Set the O-time at the setting mode 2. dEF and the range is 0~30sec

4. Adjust the operating current by the current knob

- 1) Set the operating current based on the rated current that is described in the name plate. Generally set the 110~115% of the real load current in the normal load condition
- 2) There are 3 types according to the current range (6 / 36 / 60). When you use the external CT you can see the real current by setting the CT ratio
- 3) You can easily set the current value by refer to the load rate which is displayed on the bargraph (Approx. 90% load rate)

5. Check the setting state by the display key

- 1) In normal condition it display the maximum current among the three phase current
- 2) Each time you press the "Display" button you can see the current and values
- 3) If no button is pressed for 3~4 seconds. It returned to the normal condition

6. Check the causes of the fault by look at the display unit

The causes of the fault is switched on and off for 0.5sec interval. If you press the "Display" button at this time, you can see the values and the causes of the fault







Zero current sensitivity setting

Sensitivity	DIP S/W				
(mA)	1	2	3	4	
100	0	0	0	0	
200	1	0	0	0	
500	0	1	0	0	
1000	0	0	1	0	
1500	0	0	0	1	
2000	0	0	1	1	
2500	1	1	1	1	

Note) 1. Please use ZCT for LS EM



Operation and Setting

IMP Series





1. Test/Reset

- 1) Check wires.
- 2) Press the Test/Reset key once. Then "TEST" is displayed and the EMPR is tripped.
- 3) Press again the Test/Reset key to reset the EMPR. Note) While the motor is running, the Test/Reset key does not work.

2. Setting

- 1) Press the Test/Reset key once. Then "TEST" is displayed and the EMPR is tripped.
- 2) Press the Enter key. Then "P-99" is displayed. Use the Up/Down keys to change the password.
- 3) Press the Enter key to enter A-gr setup mode.
- Use the Up/Down keys to select a group and Press the Enter key to enter the selected group. Press the Test/Reset key to move back to the previous mode.
- 4) In the A-Grp mode, Press the Enter key. Then "1.CHA" is displayed. Use the Up/Down keys to select an item and Press the Enter key to enter the selected item. Press the Test/Reset key to move back to the previous mode.
- 5) Use the Up/Down keys to set up the value and Press the Enter key to save it. Note) When the power is supplied first or is resupplied after a power failure, must set up the date in b-gr, 5.S-d. Set up the rated current S/W while the power is off.

3. Quick Setup

- 1) Press the "Up and Enter" keys at the same time. "UPLD" is displayed and settings are uploaded to the display.
- 2) Insert the display to the body without settings, and then press the Test key to enter the test mode.
- Press the "Down and Enter" keys at the same time. "TEST" is displayed and downloading is completed.
- 4) Press the Test key to return to the normal mode. Note) Communication settings cannot be uploaded or downloaded.

4. Setting Checkup

- 1) Press the Enter key.
- 2) Use the Up/Down keys to select a group and Press the Enter key to enter the selected group. Press the Test/Reset key to move back to the previous mode.
- 3) Use the Up/Down keys to select an item and Press the Enter key to enter the selected item.
- 4) Press the Enter key again to check settings.

5. Failure Event Checkup

- 1) Press the Up and Down keys at the same time to display "1.O-C" (recent failure events). Note) When no failure events are stored, "1.non3" is displayed.
- 2) Use the Up/Down keys to select an event and press the Enter key to go to the selected event.
- 3) The R-phased failure current is displayed. Every time the Down key is pressed, S-phased failure current, Tphased failure current, overload rate and date are displayed one after the other.
- 4) Press the Test/Reset key to move back to the previous mode.
- 5) Press the Up and Down keys at the same time to get out of the failure event checkup mode.

6. Forced Thermal Reset

When the system is tripped while it is in the thermal inverse time mode, if you want to turn the EMPR into the cold mode by resetting the motor's heat amount, Press the Enter and Test/Rest keys at the same time.

* When a trip occurs due to the thermal excess current, if the motor is started right after it is reset, as the motor is hot, it is highly likely that the motor is tripped again.

Operation and Setting

IMP Series





Group	Menu	Setting Value	Description	Default Value		
Α	15110	dEE/tb/n-tb	Operation Characteristics			
	il HH		(Definite/Thermal Inverse/Inverse)	n-th (inverse)		
	2.0-E 1~60s		Operation Time (sec)	60		
Э.с	3.d - E	1~200s	Delay Time (sec)	200		
	4[0.5~10A/5~100A	Rated Current (10/100A)	10/100A		
	5.0 Er	0.25, 0.5, 1~200	CT Ratio (4 times, twice, once)	1 Note)		
	6.Loc	OFF, 200~800%	Lock Protection (sec)	OFF		
	7.SEL	OFF, 150~500%	Stall Protection (sec)	OFF		
	8.P-F	OFF/On	Open Phase	OFF		
	<u>9</u> .P-U	OFF, 10~70%	Unbalance Protection (%)	OFF		
	IQ.rP	OFF/On	Reverse Phase	OFF		
	11.00	OFF, 30~90%	Under Current Protection (%)	OFF		
-12.9F	المح	0FE 0.03 0.05/0.1~3A	Ground Fault Operation Current	OFF		
	10.97	011, 0.00, 0.00, 0.1 0/	(Zero sequence CT)			
	170	OFF 20~500% (El Cmin)	Ground Fault Operation Current	OFF		
	חצבי		(Residual circuit)			
	IKst	0.05, 0.1~1.0s	Ground Fault Operation Time	-		
	15.9d On/OFF		Ground Fault Delay During Start	ON		
	16. I C	OFF, 500~1000%	Instantaneous Protection (%)	OFF		
	17.10	I-tp, I-AL, U-C, OrH, ALo	AL(07-08) contact setting	I-tp		
		I-tp	Instantaneous-current trip and warning	-		
		I-AL	Instantaneous-Current warning only	-		
		U-C	Under-Current warning only	-		
		OrH	Run Time Elapsed warning only	-		
		ALo	Activating 18.Ar. Menu	-		
	18.8r	On, 60~110%/10(%)	In case of ALO setting is done	not use		
		On	On-load status (I > 0A) signal	-		
		60~110%	Over-current waring signal (over the setting value)	-		
	19.c S	1a1b, 2a, 2b	Contact (95-96, 97-98) Setting	1a1b		

Setting Menu (A Group)

Note) 1. When the rated current S/W is 100A, the CT ratio is not displayed. 2. Some menus are not displayed if relevant functions are not available.

* Contact operation exemplification (Menu 19. cS)

10.0	o		Contact o	Default Value		
19.05	Setting Value	Motor state	95-96	97-98	Delault Value	
		Normal running	NC	NO		
	1a1b	Ground/Leakage Fault	NO	NC		
		Fault operation (except Ground fault)	NO	NC		
		Normal running	NO	NO		
2a		Ground/Leakage Fault	NO	NC	1a1b	
	Fault operation (except Ground fault)	NC	NO			
		Normal running	NC	NC		
	2b	Ground/Leakage Fault	NC	NO		
-		Fault operation (except Ground fault)	NO	NC		

IMP Series

Setting Menu (B Group)

Group	Menu	Setting Value	Description	Default Value
В	18-1	On/OFF	Electric Reset	On
	2.8-r	OFF, 1~20 min	Automatic Reset	OFF
	Br-E	Hour/Minute	Run Time	Time Check
	45rt	OFF, 1~8760Hour Run Time Setup (Hour)		-
	5.s-d	2009/01.01/00:00	YY/MM/DD/ HH:MM (View/Setup)	
	6.trt	Day/hour:minute	Total Run Time	Time Check
	Rt-d	0.5~10/5~100A	Analog output A420 Mod	
	RAdr	1~247	Communication Address	
	6.6PS	96/192/384	Communication Speed	M485 Model
	c.5-P	On/OFF	SWAP	

Note) 1. When the power is supplied first or is resupplied after a power failure, must set up the date (5.S-d). 2. Automatic reset is only possible in case of an excess current trip.

Operation Display

Display	Description	Remark	
0 - C	Over Current Trip	Operate within predefined time.	
U - C	Under Current Trip	Operate within 3 seconds.	
P - F	Open Phase Trip	Operate within 1.5 seconds when the unbalance rate is over 70%.	
P - U	Unbalance Trip	Operate within 3 seconds.	
Loc	Lock Trip	Operate within 0.5 seconds.	
SEL	Stall Trip	Operate within 3 seconds.	
r - P	Reverse Phase Trip	Operate within 0.1 second.	
9 - F	Ground Fault Trip	Operate within predefined time.	
Sho	Instantaneous Trip	Operate within 0.05 seconds.	
0 r H	Elapsed Time (No Trip)	The operation time is reset when the Reset key is pressed.	
[Ecc	Communication Fault between Body and Display (Press the ENTER/RESET key to return to the normal mode)		



de) Note) kW, kVar, and V indicate the specification of the voltage models (under development).

IMP Specifications for Low Voltage 3-Phase Induction Motors (Reference)

Full Load Current	IMP Settings			Estemal OT	Moto	or Output (Less than	ı kW)
for the Motor	Current Selection S/W	Wire Tunnel	CT ratio	External CI	220V	380V	440V
0.7A or less		4 times	0.25	-	0.1	0.18	0.2
0.7~1.6A	0.5~10A	Twice	0.5	-	0.25	0.55	0.6
1.6~8A		Once	1	-	1.5	3	3.7
7~100A	5~100A	Once	1	-	25	45	55
90~120A		Once	30	SCT-150	30	55	55
120A~160A		Once	40	SCT-200	45	75	90
160~240A		Once	60	SCT-300	55	110	132
240~320A	0.5~10A	Once	80	SCT-400	90	160	160
320~400A		Once	100	500 : 5	110	200	200
400~480A		Once	120	600 : 5	132	250	250
480~640A		Once	160	800 : 5	160	320	320

Note) 1. This table is written based on the full load current. 2. The CT is selected as a reference for the EMPR's current setting range.

Analog (DC 4~20mA) Output / Communication

- The biggest current out of measured 3-phase currents is converted into DC 4mA~20mA and the current measured remotely by digital meter can be displayed.
- 2) When there is no current, 4mA is sent. If the current goes beyond the predefined value, 20mA is sent.
 - Output Current = $\frac{16\text{mA}}{\text{Setting}} \times \text{Load Current} + 4\text{mA}$ (Settings are changed in A.t-d of b-gr)
- 3) When the system is the 0.5A~10A setting mode, measurement starts from 0.3A. When the system is the 5A~100A setting mode, measurement starts from 3A. Thus, when the current is under 0.3A (3A), 0A is measured and output is 4mA. (To measure the load current correctly, an appropriate CT should be used). Note) The allowable burden is less than 500 Ω.

Considering the receiver resistance (usually 250 Q) and track resistance), the shielding cable should be used.

Communication Spec. :

Refer to 41 page and LSIS Homepage (www.lsis.biz)



< Analogue output when the output is set to be 0.5A (5A) >



Dimensions

GMP Series



Dimensions GMP Series



0.19kg/0.21kg



0.14kg/0.16kg



Dimensions

GMP Series



Terminal arrangement



Note) 1. Only for the GMP60-TZR modle. 2. Aux. Contacts are operate when power applied.

Dimensions DMP Series







*Aux. contact wire size

: below 8[mm²]

Mounting dimensions



DMP□-S DMP□-SZ DMP□-Sa DMP□-Sa





Mounting dimensions



ℯ₽

0.64kg

Panel mounting





 Note) 1. In extension type, the digital EMPR is calibrated with combining the display unit and mainbody so, please cautious not to combine the display unit and mainbody with different part No.
 2. The 07-08 contacts are the ZCT input terminal (Digital EMPR with ground fault function)

Dimensions

DMP Series



Panel mounting





Note) 1. In extension type, the digital EMPR is calibrated with combining the display unit and mainbody so, please cautious not to combine the display unit and mainbody with different part No.
 2. The 07-08 contacts are the ZCT input terminal (Digital EMPR with ground fault function)

Dimensions IMP Series

One-Body Type # 8.8.8.8.# LS 68 90 64 باهمامامامامام 7.3 135.5 109.3 U/2/T1 V/4/T2 W/6/T3 # 8.8.8.8. U Ø17 LS ъĮ 1 | 53.5 Separate BOdy Type $\otimes \bigcirc \otimes$ Ates A2e 95+1-96 97-1-9 0000008000 68 90 64 Έ ₽ جامحممم 82 109.3 121.3 4.2 V/4/T2 U/2/T1 W/6/T3 P U

Panel mounting

Ø17 10



ni li

Note) The cable should be purchased separately (1m/1.5m/2m/3m).

-

53.5

Wiring method

GMP Series



Note) 1c(N) Type: Fail-safe operation(No volt release) contact type (When power applied the Aux. contact operate) 1c(R) Type: Non-fail-safe operation contact type





GMP60-3TZ, TZR GMP60-3TN, TNR GMP60-3T, 3TR



EMPR

Note) 1. The Z1, Z2 are the ZCT input terminal (GPM60-3TZ/TZ type) 2. Aux. contacts are operate when power applied.

Wiring method

DMP Series



Note) When the single-phase motor is used, reverse phases protection should be set off.







Wiring method

IMP Series



Note) 1. When the zero-phase-sequence current transformer is used to detect ground faults, connect the ZCT. 2. When the single-phase motor is used, all phases are connected except the S phase, and open-phase, unbalance and ground fault should be set OFF.

Terminal layout



Communication specification - Operation mode: Differential

- Distance: Max. 1.2km
- General RS-485 shielded twist 2-pair cable
- Baud rate: 9600/19200/38400bps
- Transmission method: half-Duplex
- Max. In/Output voltage: -7V~+12V

Terminal Configuration

Engrave	Description	Remark	
A1(+), A2(-)	Input terminal for operation power	AC/DC 85~245V, AC/DC 24~36V	
95-96	When the power is ON (NC contact output)	In case of an instantaneous trip, if 17.lo is ALT, it is NC, and if 17.lo is Trip, it is NO.	
97-98	When the power is ON (NC contact output)	In case of an instantaneous trip, regardless of 17 .10 setup, it is NC.	
07-08	Converted to the NC mode only when an instantaneous trip occurs.		
Z1, Z2	Output terminal for the zero-phase sequence current transformer	Specific ZCT (for the EMPR)	
TRX(+)	RS485 terminal (TRX+) Or 4~20mA (+) output	M405 A400 Time	
TRX(-)	RS485 terminal (TRX-) Or 4~20mA (-) output	101485, A420 Type	
10A/100A	Max. rated current change S/W	10A : 0.5~10A, 100A : 5~100A	
VR/VS/VT	3-phase voltage input terminal		
05-06	Output terminal for voltage protection		

Note) 1. The 3-phase voltage input terminal and 05-06 output terminal should be connected only for voltage protection models, which will be released in the future. 2. For RS485 connection, the terminal resistance should be 120 Q

^{3.} For 4~20mA current, the maximum burden should be less than 500 $\ensuremath{\Omega}$.

Specification

Туре	Model	Primary current	Secondary	Burden(VA)	Tunnel hole [mm]	Front mounting EMPR	Remarks		
3CT type	3CT-23	80, 100, 150, 180, 200A		1.5	21×21	GMP22/40/60T			
	3CT-43	100, 150, 200, 250, 300,	5A		27×27	DMP/IMP series			
		350, 400A			EIAEI	GMP60-3T/3TN/3TZ	1) Class: 1.0		
	3CT-63	400, 500, 600A			45×30	GMP22/40/60T	2) Insulation voltage: 690V		
	DCT-100	100A		5	28.5×33.5		3) Withstand voltage:		
	DCT-150	150A	5A				4kV/Imin		
2CT type	DCT-200	200A				GMP22/40/60T	4) Overcurrent strength:		
	DCT-300	300A					40×In		
	DCT-400	400A					5) Insulation Resistance:		
	SCT-100	100A		5	27.5×32.5		10Μ Ω		
	SCT-150	150A				DMP/IMP series	(DC 500V Megger)		
1CT type	SCT-200	200A	5A			GMP60-3T/3TN/3TZ	6) Frequency: 50/60Hz		
	SCT-300	300A				GMP22/40/60T			
	SCT-400	400A							

 * Ref. When secondary cable is 2.5mm², 3m length burden is 0.52VA.

Combination of 3 SCTs

3CT



Accessories

CT, ZCT, Cable and Terminal

ZCT (Zero Sequence CT)

Ratings

Туре	Diameter (A)	Ratio	Weight (kg)	Model	
ZCT, D30	30		0.5	LZT-030	
ZCT, D50	50	100mA/40~55mV	0.7	LZT-050	
ZCT, D65	65	200mA/100mV	0.9	LZT-065	
ZCT, D80	80		1.5	LZT-080	

Dimension



ZCT 50, 65, 80										
					+ + + +		t (mm)			
Model	Α	В	С	D	Е	F	G	н	1	Ø
LZT-050	50	25	131	100	122	7	32	36	114	6
LZT-065	65	26	143	114	133	7	39	37	126	6
LZT-080	80	34	174	160	180	7	40	40	151	6

Cher Options

Applicable Type DMP, IMP Series Spec. 1m, 1.5m, 2m, 3m, 4m * Panel mount: Extension cable

Terminal Block

Applicable Type	DMP Series, GMP60-3T, 3TZ, 3TN				
Spec.	60A blelow				

EMPR Curves



<Class20>



<Class60>





<Class30>



<Definite Curves>



Direct mounting EMPR new/old comparative table



Note) If you want to use Metasol EMPR with GMC Contactors, only tunnel type EMPR is available.

Certificates

A Species of Certification			Certificates				
A Species of Standard		Safety certi	IEC	UL	GB	Gosstandart	IEC
	Mark or certification	S S Martz	CE	c UL US		COST .	KEMA
Tune	\	J-IVIAIK	CL Europa		Ctic	Bussia	NLIVIA
туре	011000 00	Norea	Europe	U.S.A/Canada	China	Russia	Inetheriands
	GMP22-2P GMP22-3P			•			
	GMP22-3Fh						•
	GIVIF22-23						
	GMP22_35						
	CMP22_0T						
	GMP22-3T						
	GMP22-3TB						
	GMP40-2P						•
	GMP40-3P	•	•				•
EMPR	GMP40-3PB				•		•
2.001.00	GMP40-2S	•	•	•	•	•	-
	GMP40-3S	•	•	•	•	•	•
	GMP40-3SR	•	•	•	•	•	•
	GMP40-2T				•		
	GMP40-3T	•	•		•		•
	GMP40-3TR	•			•		•
	GMP60-T	•	•		•		
	GMP60-TE	•			•		
	GMP80-2S	•	•	•	•	•	
	GMP80-3S	•	•	•	•	•	
	GMP80-3SR	•	•	•	•	•	
	DMP06,60-S	•	•		•	•	
	DMP06,60-Sa				•		
	DMP06,60-T	•			•		
	DMP06,60-Ta				•		
	DMP06,60-SI	•	•	•	•	•	
DIVIEN	DMP06,60-SZ	•	•	•	•	•	
	DMP06,60-Sza				•		
	DMP06,60-TZ	•	•	•	•	•	
	DMP06,60-Tza				•		
	DMP06,60-TI	•	•	•	•	•	
	IMP-C-NO		•				
IMP	IMP-C-A420		•				
	IMP-C-A485						

A Species of Certification		Approvals								
A Species of Standard		Marine classification								
	Mark or certification	KR	I loydis Register		ABS		ĴÅ dinv			
	\ \	KR	LR	BV	ABS	GL	DNV	RINA		
Туре		Korea	U.K	France	U.S.A	Germany	Norway	Italy		
	DMP06,36,60-S	•	•		•					
	DMP06,36,60-Sa	•	•		•					
	DMP06,36,60-T	•	•		•					
	DMP06,36,60-Ta	•	•		•					
	DMP06,36,60-SI	•	•							
DMPR	DMP06,36,60-SZ									
	DMP06,36,60-Sza		•							
	DMP06,36,60-TZ									
	DMP06,36,60-Tza	•	•							
	DMP06,36,60-TI	•								



Safety Instructions

• For your safety, please read user's manual thoroughly before operating.

- · Contact the nearest authorized service facility for examination, repair, or adjustment.
- Please contact qualified service technician when you need maintenance.
 Do not disassemble or repair by yourself!
- · Any maintenance and inspection shall be performed by the personnel having expertise concerned.



www.lsis.com

· According to The WEEE Directive, please do not discard the device with your household waste.



Head Quarter	Overseas Branches				
LS-ro 127(Hogye-dong) Dongan-gu, Anyang-si, Gyeonggi-Do, 14119, Korea	•LSIS Shanghai Office (China)				
Tel: 82-2-2034-4902, 4684, 4429 Fax: 82-2-2034-4555	Tel: 86-21-5237-9977 Fax: 86-21-5237-7189 E-Mail: ygeo@lsis.com				
	•LSIS Beijing Office (China) Tel: 86-10-5761-3127 Fax: 86-10-5761-3128 E-Mail: sson@lsis.com				
	•LSIS Guangzhou Office (China) Tel: 86-20-8326-6784 Fax: 86-20-8326-6287 E-Mail: sojhtroh@lsis.com				
	•LSIS Qingdao Office (China) Tel: 86-532-8501-6058 Fax: 86-532-8501-6057 E-Mail: sson@lsis.com				
Overseas Subsidiaries	•LSIS Chengdu Office (China) Tel: 86-28-8670-3200 Fax: 86-28-8670-3203 E-Mail: yangcf@lsis.com				
•LSIS(Dalian) Co., Ltd. (Dalian, Chin)	•LSIS ShenYang Office (China)				
Tel: 86-411-8730-7510 Fax: 86-411-8730-7560 E-Mail: jiheo@lsis.com	Tel:86-24-2321-9050 Fax: 86-24-8386-7210 E-Mail: yangcf@lsis.com				
•LSIS(Wuxi) Co., Ltd. (Wuxi, China)	•LSIS Jinan Office (China)				
Tel: 86-510-8534-6666-8005 Fax: 86-510-8534-4078 E-Mail: sunhwank@lsis.com	Tel: 86-531-8699-7826 Fax: 86-531-8697-7628 E-Mail: yangcf@lsis.com				
•LS VINA Industrial Systems Co., Ltd. (Hanoi, Vietnam)	•LSIS Co., Ltd. Tokyo Office (Japan)				
Tel: 84-4-6275-8055 Fax: 84-4-3882-0220 E-Mail: hjchoid@lsis.com	Tel: 81-3-6268-8241 Fax: 81-3-6268-8240 E-Mail: jschuna@lsis.com				
•LSIS Middle East FZE (Dubai, U.A.E.)	•LSIS Co., Ltd. Rep. Office (Vietnam)				
Tel: 971-4-886-5360 Fax: 971-4-886-5361 E-Mail: jungyongl@lsis.com	Tel: 84-8-3823-7890 E-Mail: sjbaik@lsis.com				
•LSIS Europe B.V. (Amsterdam, Netherlands)	•LSIS Moscow Office (Russia)				
Tel: 31-20-654-1420 Fax: 31-20-654-1429 E-Mail: europartner@lsis.com	Tel: 7-499 682 6130 E-Mail: info@lsis-ru.com				
•LSIS Japan Co., Ltd. (Tokyo, Japan)	•LSIS Jakarta Office (Indonesia)				
Tel: 81-3-6268-8241 Fax: 81-3-6268-8240 E-Mail: jschuna@lsis.com	Tel: 62-21-293-7614 E-Mail: dioh@lsis.com				
•LSIS USA Inc. (Chicago, U.S.A.)	•LSIS Bangkok Office (Thailand)				
Tel: 1-800-891-2941 Fax: 1-847-383-6543 E-Mail: sales.us@lsis.com	Tel: 66-2-053-9133 E-Mail: sjleet@lsis.com				

2018. 10 Specifications continuous pro

Specifications in this catalog are subject to change without notice due to continuous product development and improvement.

© 2012. 06 LSIS Co.,Ltd. All rights reserved. / (07) 2018. 10 Human Power